



## **STEAM HEATING SUPPLEMENT SERVICE**

- Low water cut-offs will be cleaned and checked for proper operation.
- Blow-down valves will be checked for proper operation.
- Return condensate pumps will be checked for proper operation.
- Check out complete boiler cycle.
- Make any necessary recommendations.

Note: Steam maintenance does not include internal cleaning of the system. During maintenance, the technician will check for internal sludging through blow-down valves. Boiler chemicals may be recommended during fall maintenance.